

§ 95.10-15

chapter. Firehose nozzles previously approved under subpart 162.027 of this chapter may be retained so long as they are maintained in good condition to the satisfaction of the Officer in Charge, Marine Inspection.

(j) In each propulsion machinery space containing an oil fired boiler, internal combustion machinery, or oil fuel unit on a vessel on an international voyage or of 1000 gross tons or more, each firehose having a combination nozzle previously approved under subpart 162.027 of this chapter must have a low-velocity water spray applicator that is also previously approved under subpart 162.027 of this chapter. The length of the applicator must be less than 1.8 meters (6 feet).

(k) Fixed brackets, hooks, or other means for stowing an applicator must be next to each fire hydrant that has an applicator under paragraph (j) of this section.

(l) Firehose shall not be used for any other purpose than fire extinguishing, drills, and testing.

(m) Fire hydrants, nozzles, and other fittings shall have threads to accommodate the hose connections noted in paragraph (l) of this section.

(n) Firehose and couplings must be as follows:

(1) Fire station hydrant connections shall be brass, bronze, or other equivalent metal. Couplings shall either:

(i) Use National Standard fire hose coupling threads for the 1½ inch (38 millimeter) and 2½ inch (64 millimeter) hose sizes, i.e., 9 threads per inch for 1½ inch hose, and 7½ threads per inch for 2½ inch hose; or

(ii) Be a uniform design for each hose diameter throughout the vessel.

(2) Where 19 millimeters (¾ inch) hose is permitted by table 95.10-5(a), the hose and couplings shall be of good commercial grade.

(3) Each section of firehose must be lined commercial firehose that conforms to Underwriters' Laboratories, Inc. Standard 19 or Federal Specification ZZ-H-451E. Hose that bears the label of Underwriters' Laboratories,

46 CFR Ch. I (10-1-07 Edition)

Inc. as lined firehose is accepted as conforming to this requirement.

[CGFR 65-50, 30 FR 17001, Dec. 30, 1965, as amended by CGD 74-60, 41 FR 43151, Sept. 30, 1976; CGD 76-086, 44 FR 2392, Jan. 11, 1979; CGD 88-032, 56 FR 35826, July 29, 1991; CGD 95-012, 60 FR 48051, Sept. 18, 1995; CGD 95-027, 61 FR 26007, May 23, 1996; CGD 95-028, 62 FR 51206, Sept. 30, 1997; USCG-2000-7790, 65 FR 58461, Sept. 29, 2000]

§ 95.10-15 Piping.

(a) All piping, valves, and fittings shall meet the applicable requirements of subchapter F (Marine Engineering) of this chapter.

(b) All distribution cut-off valves shall be marked as required by § 97.37-10 of this subchapter.

(c) For vessels on an international voyage, the diameter of the fire main shall be sufficient for the effective distribution of the maximum required discharge from two fire pumps operating simultaneously. This requirement is in addition to § 95.10-5(c). The discharge of this quantity of water through hoses and nozzles at a sufficient number of adjacent hydrants shall be at a minimum Pitot tube pressure of approximately 50 pounds per square inch.

§ 95.10-90 Installations contracted for prior to May 26, 1965.

Installations contracted for prior to May 26, 1965, shall meet the following requirements:

(a) Except as specifically modified by this paragraph, the requirements of §§ 95.10-5 through 95.10-15 shall be complied with insofar as the number and general type of equipment is concerned. Existing equipment, except firehose nozzles and low-velocity water spray applicators, previously approved, but not meeting the applicable requirements of §§ 95.10-5 through 95.10-15 may be continued in service so long as they are maintained in good condition to the satisfaction of the Officer in Charge, Marine Inspection. Minor repairs, alterations, and replacements may be permitted to the same standards as the original installations. However, all new installations or major replacements shall meet the applicable requirements in this subpart.